

ADDENDUM NO. 2

**CITY OF FRISCO
PRESTON ROAD 24-INCH WATER TRANSMISSION LINE
(Stonebrook Pkwy. to Main St./FM 3537)**

**CIP NO. 007-0039
BID NO. 1001-030
ACCOUNTING PROJECT NO. 06604**

The following revisions are hereby made to the Contract Documents for this project:

SPECIAL CONDITIONS

1. Add Special Condition SC 15 – RESTRAINED JOINTS IN CASING: All 24-inch ductile iron water pipe in casing pipe shall be restrained. No separate pay item.
2. Add Special Condition SC 16 – RESTRAINED JOINTS AT VALVES: Joints adjacent to in-line valves shall be restrained. Restrained joint lengths shall be calculated based on dead end thrust at the valves. No separate pay item.
3. Add Special Condition SC 17 – RESTRAINED JOINTS FOR OWNER SUPPLIED PIPE: Owner supplied pipe has standard push-on bell and spigot joints. If these joints are required to be restrained to resist thrust, the Contractor shall use the Megalug Series 1700 Restraint Harness.

All other provisions of the Contract Documents shall remain the same.

Bidders shall acknowledge receipt of this Addendum in the space provided in the Bid Form.

CITY OF FRISCO
February 26, 2010



By: Marty S. Paris, P.E.
Project Manager